


Nonhazardous
Class I, II, III, Division 2, Group A-G
or Class I, Zone 2, Group IIC/IIB
Hazardous (Classified) Locations



Example connection:



Wiring legend

Connection allocation example for RTD or potentiometer
– Temperature Input Module Type 9482

Channel	X1 / X2 2 Wire Input	X1 / X2 3 Wire Input	X1 / X2 4 Wire Input
	Terminals	Terminals	Terminals
0	1(I+), 4(I-)	1(I+), 3(V-), 4(I-)	1(I+), 2(V+), 3(V-), 4(I-)
1	5(I+), 8(I-)	5(I+), 7(V-), 8(I-)	5(I+), 6(V+), 7(V-), 8(I-)
2	9(I+), 12(I-)	9(I+), 11V(-), 12(I-)	9(I+), 10(V+), 11(V-), 12(I-)
3	13(I+), 16(I-)	13(I+), 15(V-), 16(I-)	13(I+), 14(V+), 15(V-), 16(I-)
4	17(I+), 20(I-)	17(I+), 19(V-), 20(I-)	17(I+), 18(V+), 19(V-), 20(I-)
5	21(I+), 24(I-)	21(I+), 23(V-), 24(I-)	21(I+), 22(V+), 23(V-), 24(I-)
6	25(I+), 28(I-)	25(I+), 27(V-), 28(I-)	25(I+), 26(V+), 27(V-), 28(I-)
7	29(I+), 32(I-)	29(I+), 31(V-), 32(I-)	29(I+), 30(V+), 31(V-), 32(I-)

The signals are connected together via resistors by an internal common ground.
Any combination of 2-, 3- and 4-wire connection is possible.

Connection allocation example thermocouples or mV-sources and external CJC

– Temperature Input Module Type 9482

Channel	Thermocouple	External CJC 2 Wire	External CJC 3 Wire	External CJC 4 Wire
	Terminals	Terminals	Terminals	Terminals
0	2(V+), 3(V-)	-	-	-
1	6(V+), 7(V-)	-	-	-
2	10(V+), 11(V-)	-	-	-
3	14(V+), 15(V-)	-	-	-
4	18(V+), 19(V-)	-	-	-
5	22(V+), 23(V-)	-	-	-
6	26(V+), 27(V-)	25(I+) 32(I-)	25(I+) 29(I+) 32(I-)	25(I+) 28(I-) 29(I+) 32(I-)
7	30(V+), 31(V-)			

The signals are connected together via resistors by an internal common ground.

The Type 9482 Temperature Input Module is designed to receive up to 8 input signals from 2-/3- or 4-wire RTDs and potentiometers or up to eight thermocouples and mV sensors. Via the channels 6 and 7 a connection of an external cold junction compensation (CJC) via an RTD is also possible. The module transmits those signals to the IS1 CPU & Power Module.

The module is nonincendive for installation in a Class I, II, III, Division 2, Group A-G or Class I, Zone 2, Group IIC/IIB hazardous location according to NEC Article 504/505 or Canadian Electrical Code, CSA C22; Providing intrinsically safe connections for Class I, Division 1, Groups A-G or Class I, Zone 0, Group IIC/IIB hazardous locations listed below.

Entity parameters for wiring configuration are on the next pages.

Notes:

- Intrinsically safe apparatus may be mV sources, thermocouples, CJC's, RTDs, potentiometers or an Approved System or Entity device connected in accordance with the manufacturer's installation instructions.
- For Entity concept use the appropriate parameters from above to ensure the following:
 $V_{oc} \text{ or } V_t \leq V_{max}$ $C_a \geq C_i + C_{leads}$
 $I_{sc} \text{ or } I_t \leq I_{max}$ $L_a \geq L_i + L_{leads}$
- The values of La and Ca in the tables on the next sheets are the maximum values for combined inductance and capacitance (including cable inductance and capacitance). The values for La and Ca marked in grey are the values determined according to curves and tables of IEC 60079-11, Annex A. These grey marked values may be used for assessment as per IEC 60079-14, intrinsically safe circuits with only one source of power.
- Suitable separation must be maintained between wiring of each I.S. input channel.
- For Installation in Division 2 or Zone 2 see Certification drawing for IS1 resp. IS1+ Remote I/O System No. 9400 6 031 004 1 or 9400 6 031 006 1 as part of the documentation of the CPU & Power Modules.

2016	Date	Name
Drawn by	25.10.	Bagusch
Checked		Kaiser
01	09.03.2018	Bagusch
Version	Date	Name

Certification drawing

Temperature Input Module
Type 9482/33-08-1*

9482 6 031 002 1

Scale
none

Sheet
1 of 4

Agency
FM

Rep. f.

Rep. t.

A4

Entity parameters for wiring configuration – Temperature Input Module Type 9482

General explanations:

Grounded - the channels are connected via a common ground together by installation.
Ungrounded - the channels are installed galvanically separated to each other and to ground

The source is linear in all applications.

If an Ui is applied at one channel, the Ui might occur in addition to Uo at another channel. Therefore the La and Ca values are calculated with
 $Voc\ ext = Vi + Voc$.

The stated Vi is a sum over all inputs.

Ungrounded only RTD and potentiometer

For connection of up to 8 passive, galvanically isolated and ungrounded I.S. circuits.

2-Wire:		Connector X1 / X2 – Channel 0 (1/4); Channel 1 (5/8) up to Channel 7 (29/32)											
Input		Voc = 6.42 V	$Vi = n/a$			Voc ext = n/a			$Isc = 6.5\ mA$			$P_o = 10.5\ mW$	
3-Wire:		Connector X1 / X2 – Channel 0 (1/3/4); Channel 1 (5/7/8); up to Channel 7 (29/31/32)											
Input		Voc = 6.42 V	$Vi = n/a$			Voc ext = n/a			$Isc = 7.8\ mA$			$P_o = 12.5\ mW$	
4-Wire:		Connector X1 / X2 – Channel 0 (1/2/3/4); Channel 1 (4/6/7/8); up to Channel 7 (29/30/31/32)											
Input		Voc = 6.42 V	$Vi = n/a$			Voc ext = n/a			$Isc = 9.8\ mA$			$P_o = 15.7\ mW$	
		CL I, DIV 1, A,B / Zone 0, GP IIC						CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC					
L_a [mH]	100	50	20	2	0.2	0.02	0.002	100	50	20	2	0.2	0.02
C_a [μ F]	1.1	1.2	1.4	2.0	3.2	7.0	25	5.8	6.3	7.1	10	19	51

Ungrounded RTD or potentiometer connected in a mixed configuration with U_i

For connection of up to 8 passive, galvanically isolated and ungrounded I.S. circuits. Thermocouples and external CJC circuit might also be connected, their calculation is below. Calculated with the following maximum values:

2-Wire:		Connector X1 / X2 – Channel 0 (1/4); Channel 1 (5/8) up to Channel 7 (29/32)											
Input		Voc = 6.42 V	$Vi = 6.5\ V$			Voc ext = 12.92 V			$Isc = 13.1\ mA$			$P_o = 42.2\ mW$	
3-Wire:		Connector X1 / X2 – Channel 0 (1/3/4); Channel 1 (5/7/8); up to Channel 7 (29/31/32)											
Input		Voc = 6.42 V	$Vi = 6.5\ V$			Voc ext = 12.92 V			$Isc = 15.7\ mA$			$P_o = 50.6\ mW$	
4-Wire:		Connector X1 / X2 – Channel 0 (1/2/3/4); Channel 1 (4/6/7/8); up to Channel 7 (29/30/31/32)											
Input		Voc = 6.42 V	$Vi = 6.5\ V$			Voc ext = 12.92 V			$Isc = 19.6\ mA$			$P_o = 63.3\ mW$	
		CL I, DIV 1, A,B / Zone 0, GP IIC						CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC					
L_a [mH]	100	50	20	5	1	0.5	0.2	100	20	10	2	1	0.5
C_a [μ F]	0.19	0.25	0.31	0.40	0.54	0.63	0.78	1.3	1.7	1.9	2.5	3.0	3.5

2-Wire:		Connector X1 / X2 – Channel 0 (1/4); Channel 1 (5/8) up to Channel 7 (29/32)											
Input		Voc = 6.42 V	$Vi = 3.5\ V$			Voc ext = 9.92 V			$Isc = 10\ mA$			$P_o = 24.9\ mW$	
3-Wire:		Connector X1 / X2 – Channel 0 (1/3/4); Channel 1 (5/7/8); up to Channel 7 (29/31/32)											
Input		Voc = 6.42 V	$Vi = 3.5\ V$			Voc ext = 9.92 V			$Isc = 12\ mA$			$P_o = 29.8\ mW$	
4-Wire:		Connector X1 / X2 – Channel 0 (1/2/3/4); Channel 1 (4/6/7/8); up to Channel 7 (29/30/31/32)											
Input		Voc = 6.42 V	$Vi = 3.5\ V$			Voc ext = 9.92 V			$Isc = 15\ mA$			$P_o = 37.3\ mW$	
		CL I, DIV 1, A,B / Zone 0, GP IIC						CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC					
L_a [mH]	100	50	20	1	0.1	0.05	0.02	100	50	20	1	0.1	0.05
C_a [μ F]	0.40	0.47	0.56	0.92	1.6	2.0	2.8	2.3	2.5	2.9	5.1	9.8	13

			2016	Date	Name	Certification drawing Temperature Input Module Type 9482/33-08-1*						Scale none	
			Drawn by	25.10.	Bagusch								
			Checked		Kaiser							Sheet 2 of 4	
01	09.03.2018	Bagusch											
Version	Date	Name							Rep. f.	Rep. t.	Agency FM		
													A4

Grounded RTD or potentiometer connected in a mixed configuration with Vi

For connection of up to 8 passive I.S. circuits. Thermocouples and external CJC circuit might also be connected, their calculation is below.
Calculated with the following maximum values:

2-Wire:	Connector X1 / X2 – Channel 0 (1/4); Channel 1 (5/8) up to Channel 7 (29/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V			Isc = 47.9 mA		P _o = 155 mW				
3-Wire:	Connector X1 / X2 – Channel 0 (1/3/4); Channel 1 (5/7/8); up to Channel 7 (29/31/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V			Isc = 58.5 mA		P _o = 189 mW				
4-Wire:	Connector X1 / X2 – Channel 0 (1/2/3/4); Channel 1 (4/6/7/8); up to Channel 7 (29/30/31/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V			Isc = 68.8 mA		P _o = 222 mW				
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	9	5	2	1	0.5	0.2	0.1	40	20	10	5	1	0.5	0.1
C _a [μ F]	0.23	0.31	0.41	0.50	0.60	0.76	0.93	0.94	1.3	1.6	1.9	2.9	3.4	5.6

2-Wire:	Connector X1 / X2 – Channel 0 (1/4); Channel 1 (5/8) up to Channel 7 (29/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V			Isc = 36.6 mA		P _o = 91 mW				
3-Wire:	Connector X1 / X2 – Channel 0 (1/3/4); Channel 1 (5/7/8); up to Channel 7 (29/31/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V			Isc = 44.8 mA		P _o = 111 mW				
4-Wire:	Connector X1 / X2 – Channel 0 (1/2/3/4); Channel 1 (4/6/7/8); up to Channel 7 (29/30/31/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V			Isc = 52.6 mA		P _o = 131 mW				
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	17	10	5	2	1	0.2	0.02	71	50	10	2	1	0.2	0.02
C _a [μ F]	0.34	0.46	0.58	0.74	0.78	1.3	2.8	1.4	1.8	2.9	4.2	4.9	7.8	20

Ungrounded Thermocouple and mV Sources in a mixed configuration with Vi

For connection of up to 8 passive or active, galvanically isolated and ungrounded I.S. circuits. RTD and potentiometer might also be connected, their calculation is above. The external CJC might also be connected, the calculation is below. Calculated with the following maximum values:

	Connector X1 / X2 – Channel 0 (2/3); Channel 1 (6/7) up to Channel 7 (30/31)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V			Isc = 6.53 mA		P _o = 21.1 mW				
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	100	50	10	5	1	0.5	0.2	100	50	10	1	0.5	0.2	0.1
C _a [μ F]	0.30	0.32	0.38	0.42	0.55	0.63	0.79	1.5	1.6	1.9	3.0	3.5	4.6	5.7

Grounded Thermocouple and mV Sources in a mixed configuration with Vi

For connection of up to 8 passive or active I.S. circuits. RTD and potentiometer might also be connected, their calculation is above. The external CJC might also be connected, the calculation is below. Calculated with the following maximum values:

	Connector X1 / X2 – Channel 0 (2/3); Channel 1 (6/7) up to Channel 7 (30/31)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V			Isc = 25 mA		P _o = 81 mW				
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	72	50	10	2	1	0.5	0.2	100	20	5	1	0.5	0.2	0.1
C _a [μ F]	0.17	0.22	0.34	0.46	0.53	0.62	0.78	1.2	1.6	2.1	3.0	3.5	4.5	5.7

	Connector X1 / X2 – Channel 0 (2/3); Channel 1 (6/7) up to Channel 7 (30/31)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V			Isc = 19.2 mA		P _o = 48 mW				
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	100	50	10	2	1	0.2	0.02	100	20	5	1	0.5	0.1	0.02
C _a [μ F]	0.33	0.43	0.60	0.80	0.92	1.3	2.8	2.2	2.9	3.6	5.0	6	9.8	20

Ungrounded RTD for external CJC connected in a mixed configuration with Vi

For connection of up to 8 passive, galvanically isolated and ungrounded I.S. circuits. Thermocouples and RTD and potentiometer might also be connected, their calculation is above. Calculated with the following maximum values:

2-Wire:	Connector X2 – Channel 6 and 7 (25/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V	Isc = 13.1 mA			P _o = 43 mW					
3-Wire:	Connector X2 – Channel 6 and 7 (25/29/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V	Isc = 17.4 mA			P _o = 56.2 mW					
4-Wire:	Connector X2 – Channel 6 and 7 (25/28/29/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V	Isc = 26.1 mA			P _o = 84.3 mW					
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	66	50	20	5	1	0.5	0.2	100	20	5	1	0.5	0.2	0.1
C _a [μ F]	0.17	0.21	0.29	0.39	0.53	0.62	0.78	1.2	1.6	2.1	2.9	3.5	4.5	5.7

2-Wire:	Connector X2 – Channel 6 and 7 (25/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V	Isc = 10 mA			P _o = 24.9 mW					
3-Wire:	Connector X2 – Channel 6 and 7 (25/29/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V	Isc = 13.4 mA			P _o = 33.2 mW					
4-Wire:	Connector X2 – Channel 6 and 7 (25/28/29/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V	Isc = 20.1 mA			P _o = 49.7 mW					
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	100	50	10	2	1	0.2	0.02	100	20	5	1	0.5	0.1	0.02
C _a [μ F]	0.31	0.43	0.60	0.80	0.91	1.3	2.8	2.2	2.8	3.6	5.0	6	9.8	20

Grounded RTD for external CJC connected in a mixed configuration with Vi

For connection of up to 8 passive I.S. circuits. Thermocouples and RTD and potentiometer might also be connected, their calculation is above. Calculated with the following maximum values:

2-Wire:	Connector X2 – Channel 6 and 7 (25/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V	Isc = 47.9 mA			P _o = 155 mW					
3-Wire:	Connector X2 – Channel 6 and 7 (25/29/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V	Isc = 68.6 mA			P _o = 222 mW					
4-Wire:	Connector X2 – Channel 6 and 7 (25/28/29/32)													
Input	Voc = 6.42 V	Vi = 6.5 V			Voc ext = 12.92 V	Isc = 87.1 mA			P _o = 281.1 mW					
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	5.6	5	2	1	0.5	0.2	0.1	25	20	10	5	1	0.5	0.1
C _a [μ F]	0.25	0.27	0.39	0.48	0.58	0.75	0.92	1	1.1	1.5	1.9	2.8	3.4	5.6

2-Wire:	Connector X2 – Channel 6 and 7 (25/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V	Isc = 36.8 mA			P _o = 91.1 mW					
3-Wire:	Connector X2 – Channel 6 and 7 (25/29/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V	Isc = 52.6 mA			P _o = 131 mW					
4-Wire:	Connector X2 – Channel 6 and 7 (25/28/29/32)													
Input	Voc = 6.42 V	Vi = 3.5 V			Voc ext = 9.92 V	Isc = 66.8 mA			P _o = 166 mW					
CL I, DIV 1, A,B / Zone 0, GP IIC							CL I, DIV 1, C-G / Zone 0, GP IIB/IIIC							
L _a [mH]	10	5	2	1	0.2	0.1	0.02	44	20	10	2	1	0.1	0.02
C _a [μ F]	0.37	0.53	0.71	0.85	1.3	1.6	2.8	1.5	2.3	2.8	4.1	4.9	9.8	20

			Certification drawing						Scale none
			Temperature Input Module						
			Type 9482/33-08-1*						
			9482 6 031 002 1						Agency FM
			Rep. f.			Rep. t.			